Ref. Certif. No.
TR-000843

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	SOCKET-OUTLETS
Name and address of the applicant	MONO ELEKTRIK MALZEMELERI SAN. VE DIS TIC. YASSIOREN KOYU HADIMKOY CAD. NO:162 ARNAVUTKOY /ISTANBUL Turkey
Name and address of the manufacturer	MONO ELEKTRIK MALZEMELERI SAN. VE DIŞ TIC. LTD. STI YASSIOREN KOYU HADIMKOY CAD. NO:162 ARNAVUTKOY /ISTANBUL Turkey
Name and address of the factory Note: *When more than one factory, please report on page 2*	☐ Additional information on page 2 MONO ELEKTRIK MALZEMELERI SAN. VE DIŞ TIC. LTD. STI YASSIOREN KOYU HADIMKOY CAD. NO:162 ARNAVUTKOY /ISTANBUL Turkey
Ratings and principal characteristics	16 A , 250 V ~, IP 54, INCREASED PROTECTION ,SURFACE TYPE, WITHOUT SHUTTERS, DESIGN A, SCREW-TYPE,2P+E, TWO-POLE, SINGLE AND DOUBLE, SOCKET-OUTLETS WITH SIDE EARTHING CONTACTS
Trademark (if any)	MONO
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Main Body Type Ref.: 07-117, Product catalogue number:154 XXXX 07 117, 154 XXXX 07 120, Serial Name/Serial Code: OCTANS IP54 / 154 XXXX
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013 National differences: TR Comments: TS 40 National Standard (Sheet 7=CEE 7:Sheet III)
As shown in the Test Report Ref. No. which forms part of this Certificate	495103/10-19-21.10.2019, TR-06-14-10-01/1044/00001

This CB Test Certificate is issued by the National Certification Body

TSE
Necatibey Cad. No: 112, TR-06100 Bakanliklar, Ankara, Turkey

Date: 2019-10-31

Signature: Gursel Eratak